



**NOELKER
AND HULL**
ASSOCIATES, INC.

ARCHITECTS

ADDENDUM NO. 3

Date: 01/23/2026

Project No.: 24035.04

Client: Greencastle Borough

Project: Phase 3 Façade Beautification

To: Bid Document Holders

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents, dated 22 DECEMBER 2025, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

This Addendum consists of one (1) page.

OFFICIAL RESPONSES TO RFIs:

1. What gauge metal should be used for the flashing and coping?
 - a. **Response:** For flashing and coping, 24-gauge galvanized steel is to be used.

2. What color metal is to be used? Will color samples need to be submitted along with the mortar and paint colors?
 - a. **Response:** Per notes on Sheet A101, the flashing colors are to be custom colors to match adjacent EIFS colors. Refer to Project Specifications on Sheet CS-1 which outlines submittal requirements, including sample submittal requirements; as noted, samples are to be submitted at one time for coordination of colors; bidders are to plan accordingly.

END OF ADDENDUM No. 3