



**NOELKER
AND HULL**
ASSOCIATES, INC.

ARCHITECTS

ADDENDUM NO. 1

Date: 07/21/2026

Project No.: 24035.07

Client: Greencastle Borough

Project: Greencastle Borough Plaza – Phase 4

To: Bid Document Holders

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents, dated 19 JUNE 2026, as noted below. Acknowledge receipt of this Addendum on the Bid Form. Failure to do so may subject Bidder to disqualification.

This Addendum consists of one (1) page.

OFFICIAL RESPONSES TO RFIs:

1. What Risk Category should be used in the delegated design engineering of the screen wall as required by the contract documents per Sheet A103?
 - a. **Response:** For bidding purposes, assume the screen wall is a Risk Category II per 2021 IBC Section 1604.5.

END OF ADDENDUM No. 1